



City of Chicago
Richard M. Daley, Mayor

Department of Buildings

Richard J. Monocchio
Commissioner

Permitting Services

City Hall, Room 900
121 North LaSalle Street
Chicago, Illinois 60602
(312) 744-8670
(312) 744-7839 (FAX)

Inspectional Services

120 North Racine Avenue
1st Floor
Chicago, Illinois 60607
(312) 743-7200
(312) 743-7435 (FAX)

Neighborhood Permit Centers

2550 West Addison Street
Chicago, Illinois 60618
(312) 742-2560
(312) 742-2566 (FAX)

4770 South Kedzie Avenue
Chicago, Illinois 60632
(312) 745-4240
(312) 745-4340 (FAX)

2006 East 95th Street
Chicago, Illinois 60617
(312) 745-0995
(312) 745-2018 (FAX)

<http://www.cityofchicago.org>

May 29, 2009

Mr. Daniel P. Ciral
President
Big Bay Lumber Company
1017 W. Division
Chicago, IL 60642

Re: TimberSIL Approval Letter

Dear Mr. Ciral,

TimberSIL has been approved by the City of Chicago Department of Buildings for use as a Class A Exterior Fire Rated, Rot and Decay Resistant Building Product. To receive Class A approval (as required by International Building Code) TimberSIL has successfully documented passage of the 30 minute ignition resistance test ASTM E-84-05 and the accelerated weathering test ASTM D2898.

This approval includes usage on porches and multifamily rooftop decks where code requirements specify use of fire retardant material.

Sincerely,

Asif Rahman
Chief Plan Examiner
Chicago Department of Buildings

